Missouri Department of Transportation



North Central District 902 North Missouri St. P.O. Box 8 Macon, MO 63552 (660) 385-8245 Fax (660) 385-1707 Toll free 1-888 ASK MoDOT http://www.modot.mo.gov

Dan Niec, District Engineer

ADDENDUM 001 REQUEST FOR BIDS (RFB) NUMBER: D211-003-R2 9 FOOT DIAMETER METAL PIPE

Bidders shall acknowledge receipt of Addendum 001 (ONE) by signing and including it with the original bid. The due date for receipt of bids has been extended to Tuesday, August 3, 2010 at 1:00 PM by this Addendum. Accordingly, the following clarifications, questions and answers are believed to be of general interest to all potential Bidders. All other terms and conditions remain unchanged and in full force.

| Name and Title of Signer (Print or type) | Name and Title of Department Authority |
|--|---|
| (************************************** | Jennifer Weydert, CPPB General Services Specialist |
| | |
| Bidder Signature | Missouri Department of Transportation |
| | Gennis Weydert CPB |
| (Signature of person authorized to sign) | (Authorizing Signature) |
| Date Signed: | Date Signed: July 30, 2010 |

NOTE: This signed addendum MUST be included with your response to the Request For Bid.

This addendum is published to respond to a question received from a vendor seeking clarification about the required specifications for the materials requested in the RFB.

Question: Can you provide clarification about the measurements of the corrugations? Are you sure your corrugations need to be 5-inches deep x 1-inch wide? Or are those measurements reversed?

Answer: The original specification in the RFB incorrectly stated that the corrugations of the metal pipe needed to be 5-inches deep x 1-inch wide. After further review, it has been determined that the correct measurements of the corrugations of the metal pipe need to be 5-inches wide x 1-inch deep. Please note that we will also accept 3-inches wide x 1-inch deep corrugated metal pipe.